



## Bluelight Software

902 Redwood Drive  
Loveland, CO 80538

Phone: 970-461-8554

Fax: 970-461-8555

NFPA Member  
Permit #93989593  
www.bluelightsw.com

www.efinitymobile.com  
sales@bluelightsw.com  
support@bluelightsw.com

Versatile Data Collection, Dynamic Forms Building  
Providing software solutions to service industries for decades

## FLOW TEST REPORT

### Customer Address:

Bluelight Software, LLC  
902 Redwood Drive Suite 101  
Loveland, CO 80538  
Phone: (970) 461-8554  
Fax: (970) 461-8555

Customer #: 11

Contract #: 766

Job Status: Archived

Job Name: AFSA Hydrant Flow Test Sample Report

### Site Address:

Bluelight Software, LLC  
902 Redwood Drive Suite 101  
Loveland, CO 80538  
Phone: (970) 461-8554  
Fax: (970) 461-8555

Contact: Al Riggs

Site #: 1111

Inspection Date: 2/14/2007

## FLOW TEST INFORMATION SHEET

Reason for Test: Bid Information  Design Base   
Other \_\_\_\_\_

Location of Property: 901 Redwood Drive Loveland CO 80538  
(Address) (City) (State) (County)

Date & Time of Test: Date: 2/14/2007 Time: 11:00 AM

Test Conducted By: Sam Adams Inspector General Inspection Co.  
 (Name) (Title) (Affiliation)

Test Witnessed By: Jim Beam Owner Owner  
 (Name) (Title) (Affiliation)

Source of Water Supply: Gravity  Pump  Other: \_\_\_\_\_

Name of Water District: Loveland Fire District: Loveland

Is water supply provided with PRV STA's? Yes  No

If so what is PRV outlet setting? 45 PSIG

**Flow Test Data**

FLOW AT HYDR. NO.	STATIC AT HYDR. NO.	STATIC PSIG	RESIDUAL PSIG	FLOW GPM	OUTLET COEFFICIENT	ADJUSTED GPM
7500	73	71	71	5000	0.7	4500
6000	75	74	73	3000	0.8	2500
6500	73	72	70	6000	0.7	5500
3500	73	72	71	3000	0.8	2500

Signed *Sam Adams*

Witness *Jim Beam*

