



Bluelight Software
902 Redwood Drive
Loveland, Co 80538

(970) 461-8554
(970) 461-8555

NFPA Member
Permit #93989593
www.bluelightsw.com

www.efinitymobile.com
sales@bluelightsw.com
support@bluelightsw.com

Versatile Data Collection, Dynamic Forms Building
Providing software solutions to service industries for decades

FIRE EXTINGUISHER INSPECTION

Customer Address:

Bluelight Software, LLC
902 Redwood Drive
Loveland, CO 80538
Phone: (970) 461-8554
Fax: (970) 461-8555

Site Address:

Bluelight Software, LLC
902 Redwood Drive
Loveland, CO 80538
Phone: (970) 461-8554
Fax: (970) 461-8555

Customer #: 111
Contract #: 5673466
Job Status: Completed
Job Name: NFPA10 Fire Extinguisher Inspection Sample Report

Contact: Al Riggs
Site #: 1111
Inspection Date: 1/21/2009

****Indicates question was scheduled, but was not answered.
----Indicates question was not scheduled and was therefore not answered.
N/A indicates question was not applicable for that device.

EXTINGUISHER TYPE	AREA AND LOCATION	SIZE	SERIAL NUMBER	MONTHLY INSP.	ANNUAL INSP.	6 YEAR MAINT.	LAST HYDRO DATE	REPLACED FOR HYDRO
-------------------	-------------------	------	---------------	---------------	--------------	---------------	-----------------	--------------------

Antifreeze - mechanical pump (A)	Basement Southwest corner	6 LB	83937989765	Fail	Pass	N/A	N/A	N/A
Antifreeze - gas cartridge/cylinder (A)	Floor 01 Hallway	10 LB	83927989764	Pass	Pass	N/A	1/20/2009	Yes
Inverting type soda acid or foam (A)	Floor 01 Hallway	4.5 LB	83972989767	N/A	N/A	N/A	1/20/2009	Yes
Water - mechanical pump (A)	Floor 01 Hallway	2.5 LB	83977989765	Pass	Pass	N/A	N/A	N/A
Carbon dioxide (BC)	Floor 01 Hallway	15 LB	83977989763	Pass	Pass	N/A	1/20/2009	Yes
Clean agent - refillable (BC)	Floor 01 Hallway	13 LB	83947989742	Pass	Pass	Replaced	1/20/2009	Yes
Dry chem - cartridge - refillable (BC)	Floor 01 Hallway	4.25 LB	83977985725	Pass	Pass	N/A	9/29/2006	Yes
Dry chem - stored pressure - disposable (BC)	Floor 01 Hallway	4.25 LB	82977989733	Pass	Pass	N/A	9/29/2006	Yes
Dry chem - stored pressure- refillable (ABC)	Floor 01 Lobby	4.5 LB	84977984533	Pass	Pass	Maintained	1/20/2009	Yes
Dry chem - cartridge - refillable (AB)	Floor 01 Lobby	5 LB	84958364851	Pass	Pass	N/A	1/20/2009	Yes
Antifreeze - mechanical pump (A)	Floor 01 Room 101	----	84958364853	****	****	N/A	N/A	N/A
Dry chem - cartridge - refillable (AB)	Floor 01 Room 101	5 LB	84977989733	Pass	Pass	N/A	1/20/2009	Yes
Dry chem - cartridge - refillable (A)	Floor 01 Room 102	20 LB	83977984767	Pass	Pass	N/A	1/20/2009	Yes
Dry chem - stored pressure- refillable (A)	Floor 02 Hallway	4.5 LB	83977989764	Pass	Fail	Maintained	9/29/2006	Yes
Water - stored pressure (A)	Floor 02 Hallway	4.5 LB	83977989767	Pass	Pass	N/A	9/29/2006	Yes
Wetting agent - stored pressure (A)	Floor 02 Hallway	8 LB	83977989762	Pass	Pass	N/A	1/20/2009	Yes
Wetting agent -gas cartridge/cylinder (A)	Floor 02 Hallway	5 LB	83977984764	Pass	Pass	N/A	9/29/2006	Yes
Dry chem - cartridge - refillable (AB)	Floor 02 Hallway	8 LB	8394489733	Pass	Pass	N/A	9/29/2006	Yes
Dry chem - stored pressure - disposable (AB)	Floor 02 Hallway	4.25 LB	83977989766	Pass	Pass	N/A	9/29/2006	Yes
Dry chem - stored pressure- refillable (AB)	Floor 02 Hallway	4.25 LB	83977989726	Pass	Pass	Replaced	9/29/2006	Yes
AFFF or FFFP - stored pressure (B)	Floor 02 Hallway	2.5 LB	83977954762	Pass	Pass	N/A	9/29/2006	Yes
Clean agent nonrechargeable (BC)	Floor 02 Hallway	15 LB	83527989777	Pass	Pass	N/A	9/29/2006	Yes
Dry chem - stored pressure- refillable (BC)	Floor 02 Hallway	8 LB	83977989772	Pass	Pass	Maintained	9/29/2006	Yes

Dry chem - cartridge - refillable (AB)	Floor 02	Office	4.25 LB	84958364856	Pass	Pass	N/A	1/20/2009	Yes
Dry chem - cartridge - refillable (AB)	Floor 02	Room 202	4.25 LB	84958364855	Pass	Pass	N/A	1/20/2009	Yes
Antifreeze - stored pressure (A)	Floor 03	Hallway	30 LB	83977989727	Pass	Pass	N/A	****	****
Dry chem - stored pressure - disposable (A)	Floor 03	Hallway	2.75 LB	83977989784	Pass	Pass	N/A	9/29/2006	Yes
Water gas cartridge/cylinder (A)	Floor 03	Hallway	4.5 LB	83977989788	Pass	Pass	N/A	9/29/2006	Yes
Dry chem - cartridge - refillable (ABC)	Floor 03	Hallway	6 LB	83977489774	Pass	Pass	N/A	9/29/2006	Yes
Dry chem - stored pressure - disposable (ABC)	Floor 03	Hallway	8 LB	83957989773	Pass	Pass	N/A	9/29/2006	Yes
Dry chem - stored pressure- refillable (ABC)	Floor 03	Hallway	15 LB	83977569777	Pass	Pass	Replaced	9/29/2006	Yes
AFFF or FFFP - gas cartridge/cylinder (B)	Floor 03	Hallway	6 LB	83977959773	Pass	Pass	N/A	9/29/2006	Yes
Protein foam tank (B)	Floor 03	Hallway	4.25 LB	83973989768	N/A	Pass	N/A	N/A	N/A
Clean agent rechargeable (BC)	Floor 03	Hallway	5 LB	83956989763	Pass	Pass	Maintained	1/20/2009	Yes

DEFICIENCIES

AFFF or FFFP - gas cartridge/cylinder (B)

Floor 03 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

AFFF or FFFP - stored pressure (B)

Floor 02 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Antifreeze - gas cartridge/cylinder (A)

Floor 01 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Antifreeze - mechanical pump (A)

Basement Southwest corner

Q# 4 - Monthly inspection
Fail - NOT MOUNTED PROPERLY.



Carbon dioxide (BC)

Floor 01 Hallway

Q# 1 - Hydrostatic test due
Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Clean agent - refillable (BC)

Floor 01 Hallway

Q# 1 - Hydrostatic test due
Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Clean agent nonrechargeable (BC)

Floor 02 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Clean agent rechargeable (BC)

Floor 03 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - cartridge - refillable (A)

Floor 01 Room 102

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - cartridge - refillable (AB)

Floor 01 Lobby

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - cartridge - refillable (AB)

Floor 01 Room 101

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - cartridge - refillable (AB)

Floor 02 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - cartridge - refillable (AB)

Floor 02 Office

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - cartridge - refillable (AB)

Floor 02 Room 202

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - cartridge - refillable (ABC)

Floor 03 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - cartridge - refillable (BC)

Floor 01 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - stored pressure - disposable (A)

Floor 03 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - stored pressure - disposable (AB)

Floor 02 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - stored pressure - disposable (ABC)

Floor 03 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - stored pressure - disposable (BC)

Floor 01 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - stored pressure- refillable (A)

Floor 02 Hallway

Q# 1 - Hydrostatic test due
Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - stored pressure- refillable (A)

Floor 02 Hallway

Q# 3 - Annual maintenance
Fail - BAD EXTINGUISHING AGENT

Dry chem - stored pressure- refillable (AB)

Floor 02 Hallway

Q# 1 - Hydrostatic test due
Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - stored pressure- refillable (ABC)

Floor 01 Lobby

Q# 1 - Hydrostatic test due
Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - stored pressure- refillable (ABC)

Floor 03 Hallway

Q# 1 - Hydrostatic test due
Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Dry chem - stored pressure- refillable (BC)

Floor 02 Hallway

Q# 1 - Hydrostatic test due
Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Inverting type soda acid or foam (A)

Floor 01 Hallway

Q# 1 - Hydrostatic test due
Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Water - stored pressure (A)

Floor 02 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Water gas cartridge/cylinder (A)

Floor 03 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Wetting agent - stored pressure (A)

Floor 02 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

Wetting agent -gas cartridge/cylinder (A)

Floor 02 Hallway

Q# 1 - Hydrostatic test due

Yes - SENT OUT FOR HYDROSTATIC TEST AND LEFT REPLACEMENT

NOT INSPECTED**Antifreeze - mechanical pump (A)**

Floor 01 Room 101

Q# 3 - Annual maintenance

-

Antifreeze - mechanical pump (A)

Floor 01 Room 101

Q# 4 - Monthly inspection

-

Antifreeze - mechanical pump (A)

Floor 01 Room 101

Q# 5 - Extinguisher size

-

COMMENTS

Sent several extinguishers out for hydrostatic testing and/or 6 year maintenance and left replacements.

Liability Release Statement:

The owner and/or designated representative acknowledges the responsibility of the operating condition of the component parts at the time of this inspection. It is agreed that the inspection service provided by the contractor as prescribed herein is limited to performing a visual inspection and/or routine testing, and any investigation or unscheduled testing, modification, maintenance, repair, etc., of the component parts is not included as part of the inspection work performed. It is further understood that all information contained herein is provided to the best of the knowledge of the party providing such information.



Customer: Jim Beam

1/21/2009



Inspection Technician: Sam Adams

1/21/2009